

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated 15/04/2025

It is certified that an inspection team headed by S.H. SURESH JE.

(Name of Officers with designation) from PHED inspected the NEW PRABHAT

PUBLIC SCHOOL, CHHACHERA, NUH (HR)

(Name & Address of the school) on 15/04/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 161 dated 15.04.2025

Of (PHED Lab) certified that the NEW PRABHAT PUBLIC SCHOOL, CHHACHERA

(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31/03/2026

Signature with Seal :

Sub Divisional Engineer  
P.H.E. Sub Division No. 2  
PALWAL

Name : VALI MOHD.

Designation : SUB. DIVISION ENGINEER

Name & Address of the Office / Department : PUBLIC HEALTH

ENGINEERING, DEPT (HR)

To

NEW PRABHAT PUBLIC SCHOOL  
CHHACHERA, Teh-NUH, Distt-NUH (HR)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Memo No:- 161

Date:- 15/04/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	MEW/00222/4/2025 / Private	Sample Details	Date & Time
Sender :	NEW PRABHAT PUBLIC SCHOOL	Collected By	DESHRAJ
Location :	, CHHACHERA	Collection Date	15/04/2025 at 09:02
Sample Description :	Drinking Water	Received at lab	15/04/2025 at 11:43
Latitude / Longitude :	77.091872 / 28.121582	Analysis Start Date	15/04/2025
		Analysis End Date	15/04/2025
		Sample Quantity	1 Liter

**Test Result (As Per BIS 10500 :2012)**

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<0.5	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2022)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
4	Color	<5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	158	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO <sub>3</sub>	49	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	6	75 mg/lit.	200 mg/lit.	APHA 24th Edition -3500 Ca B
8	Magnesium as Mg	8	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg-B
9	Total Alkalinity	60	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	17	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as SO <sub>4</sub>	44	200 mg/lit.	400 mg/lit.	APHA 24th Edition -4500 SO <sub>4</sub> -E
12	Fluoride as F	<0.1	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition -4500 F-D
13	Iron as Fe	<0.1	1.0 mg/lit.	1.0 mg/lit.	APHA 23rd Edition -3500 Fe-B
14	Nitrate as NO <sub>3</sub>	4.4	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO <sub>3</sub> -D
15	pH @ 25°C	7.31	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition -4500-H+ B

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in PHED MEWAT Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

TAHIR HUSSAIN ,CHEMIST  
DISTRICT WATER TESTING LABORATORY,MEWAT  
email:-chemist.mewat@phedharyana.gov.in